# **Energy performance certificate (EPC)**

APARTMENT 306
CHATSWORTH HOUSE
19 LEVER STREET
MANCHESTER
M1 1BY

Energy rating
Valid until: 27 April 2031

Certificate 0041-2008-5040-2329-6221
number:

Property type Mid-floor flat

**Total floor area** 64 square metres

## Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

## **Energy rating and score**

This property's current energy rating is D. It has the potential to be C.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

#### Breakdown of property's energy performance

## Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	System built, as built, insulated (assumed)	Good

Feature	Description	Rating
Window	Fully double glazed	Good
Main heating	Room heaters, electric	Very poor
Main heating control	Programmer and appliance thermostats	Good
Hot water	Electric immersion, off-peak	Average
Lighting	Low energy lighting in 75% of fixed outlets	Very good
Roof	(another dwelling above)	N/A
Floor	(another dwelling below)	N/A
Secondary heating	None	N/A

# Primary energy use

The primary energy use for this property per year is 229 kilowatt hours per square metre (kWh/m2).

About primary energy use

#### How this affects your energy bills

An average household would need to spend £814 per year on heating, hot water and lighting in this property. These costs usually make up the majority of your energy bills.

You could save £283 per year if you complete the suggested steps for improving this property's energy rating.

This is based on average costs in 2021 when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

# Heating this property

Estimated energy needed in this property is:

- 2,125 kWh per year for heating
- 1,874 kWh per year for hot water

### Impact on the environment

This property's current environmental impact rating is D. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year. CO2 harms the environment.

## Carbon emissions

An average household produces	6 tonnes of CO2
This property produces	2.5 tonnes of CO2
This property's potential production	2.4 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

#### ▶ <u>Do I need to follow these steps in order?</u>

# Step 1: High heat retention storage heaters

Typical installation cost	£1,200 - £1,800

Typical yearly saving £255

Potential rating after completing step 1

78 C

# Step 2: Heat recovery system for mixer showers

Typical installation cost	£585 - £725
Typical yearly saving	£28
Potential rating after completing steps 1 and 2	79 C

# Help paying for energy improvements

You might be able to get a grant from the <u>Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme)</u>. This will help you buy a more efficient, low carbon heating system for this property.

# More ways to save energy

Find ways to save energy in your home.

Who to contact about this certificate

## Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Arthur Howarth
Telephone	07514156069
Email	info@howarth-epcs.co.uk

## Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO029919
Telephone	0330 124 9660
Email	certification@stroma.com

## About this assessment

Assessor's declaration	No related party
Date of assessment	28 April 2021

Date of certificate	28 April 2021
Type of assessment	► RdSAP

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at <u>dluhc.digital-services@levellingup.gov.uk</u> or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

**Certificate number** 8803-7248-0729-1806-6693 (/energy-certificate/8803-7248-

0729-1806-6693)

Expired on 3 June 2021

<u>Help (/help)</u> <u>Accessibility (/accessibility-statement)</u> <u>Cookies (/cookies)</u>
<u>Give feedback (https://forms.office.com/e/hUnC3Xq1T4)</u> <u>Service performance (/service-performance)</u>

## **OGL**

All content is available under the <u>Open Government Licence v3.0 (https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/)</u>, except where otherwise stated



ght (https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-c