

Energy performance certificate (EPC)

FLAT 7
SAXON COURT
EASTBOURNE ROAD
PEVENSEY BAY
BN24 6ER

Energy rating

C

Valid until

11 May 2031

Certificate number

9892-1006-4205-4699-

1200

Property type

Top-floor flat

Total floor area

62 square metres

Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

Energy efficiency rating for this property

This property's current energy rating is C. It has the potential to be C.

[See how to improve this property's energy performance.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C	73 c	80 c
55-68	D		
39-54	E		
21-38	F		
1-20	G		

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says “assumed”, it means that the feature could not be inspected and an assumption has been made based on the property’s age and type.

Feature	Description	Rating
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Roof	Pitched, 300 mm loft insulation	Very good
Window	Fully double glazed	Average
Main heating	Electric storage heaters	Average
Main heating control	Manual charge control	Poor
Hot water	Electric immersion, off-peak	Average
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	(another dwelling below)	N/A
Secondary heating	Portable electric heaters (assumed)	N/A

Primary energy use

The primary energy use for this property per year is 276 kilowatt hours per square metre (kWh/m²).

▶ [What is primary energy use?](#)

Primary energy use is a measure of the energy required for lighting, heating and hot water in a property. The calculation includes:

- the efficiency of the property’s heating system
- power station efficiency for electricity

- the energy used to produce the fuel and deliver it to the property

Additional information

Additional information about this property:

- Cavity fill is recommended
- Dwelling may be exposed to wind-driven rain

Environmental impact of this property

One of the biggest contributors to climate change is carbon dioxide (CO₂). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO₂ emissions.

An average household produces	6 tonnes of CO ₂
--------------------------------------	-----------------------------

This property produces	2.9 tonnes of CO ₂
-------------------------------	-------------------------------

This property's potential production	2.2 tonnes of CO ₂
---	-------------------------------

By making the [recommended changes](#), you could reduce this property's CO₂ emissions by 0.7 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

How to improve this property's energy performance

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from C (73) to C (80).

Potential energy
rating

C

► [What is an energy rating?](#)

An energy rating shows a property's energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher this number, the lower your CO₂ emissions are likely to be.

Recommendation 1: Cavity wall insulation

Cavity wall insulation

Typical installation cost

£500 - £1,500

Typical yearly saving

£64

Potential rating after carrying out recommendation 1

76 | C

Recommendation 2: High heat retention storage heaters

High heat retention storage heaters

Typical installation cost	£1,200 - £1,800
----------------------------------	-----------------

Typical yearly saving	£69
------------------------------	-----

Potential rating after carrying out recommendations 1 and 2	
--	--



79 | C

Recommendation 3: Heat recovery system for mixer showers

Heat recovery system for mixer showers

Typical installation cost	£585 - £725
----------------------------------	-------------

Typical yearly saving	£30
------------------------------	-----

Potential rating after carrying out recommendations 1 to 3	
---	--



80 | C

Paying for energy improvements

[Find energy grants and ways to save energy in your home.](https://www.gov.uk/improve-energy-efficiency)
(<https://www.gov.uk/improve-energy-efficiency>)

Estimated energy use and potential savings

£630

Estimated yearly energy cost for this property

Potential saving	£162
-------------------------	-------------

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice \(https://www.simpleenergyadvice.org.uk/\)](https://www.simpleenergyadvice.org.uk/).

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Space heating	3489 kWh per year
----------------------	--------------------------

Water heating	1819 kWh per year
----------------------	--------------------------

Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
---------------------------	-------------------------------

Cavity wall insulation	598 kWh per year
-------------------------------	-------------------------

You might be able to receive [Renewable Heat Incentive payments \(https://www.gov.uk/domestic-renewable-heat-incentive\)](https://www.gov.uk/domestic-renewable-heat-incentive). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	Gary Branch
------------------------	-------------

Telephone	0142 489 2884
------------------	---------------

Email	garyb710@aol.com
--------------	--

Accreditation scheme contact details

Accreditation scheme	Stroma Certification Ltd
-----------------------------	--------------------------

Assessor ID	STRO002025
--------------------	------------

Telephone	0330 124 9660
------------------	---------------

Email	certification@stroma.com
--------------	--

Assessment details

Assessor's declaration	No related party
-------------------------------	------------------

Date of assessment	11 May 2021
---------------------------	-------------

Date of certificate	12 May 2021
----------------------------	-------------

► [RdSAP](#)

**Type of
assessment**

RdSAP
(Reduced data
Standard
Assessment
Procedure) is a
method used to
assess and
compare the
energy and
environmental
performance of
properties in
the UK. It uses
a site visit and
survey of the
property to
calculate
energy
performance.

This type of
assessment
can be carried
out on
properties built
before 1 April
2008 in
England and
Wales, and 30
September
2008 in
Northern
Ireland. It can
also be used
for newer
properties, as
long as they
have a
previous SAP
assessment,
which uses
detailed
information
about the

property's
construction to
calculate
energy
performance.

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk, or call our helpdesk on 020 3829 0748.

Certificate number [0578-2825-6728-9690-4651 \(/energy-certificate/0578-2825-6728-9690-4651\)](#)

Expired on 15 February 2020
